


ISO 9001:2008



DOST

May 26, 2014

TEST REPORT

Type of Test: Abrasion Test
Test Method: Method of Abrasion Test for Building Materials and Part of Building Construction (Abrasive-Paper Method- JIS 1453)
Sampling Method: As submitted
Date: May 19, 2014
Requested by: Mr. Mark Eugene Tan
 President, Stantrade Development Inc.
 Cubao, Quezon City

SAMPLE	SAMPLE DIMENSIONS (mm)	TEST CYCLES	WEIGHT LOSS (g)	TABER WEAR INDEX (TWI)
PALMECO Board 1	101.6 x 101.6	500	0.22	0.440
PALMECO Board 2	101.6 x 101.6	500	0.26	0.520


Tested by:


Emerson L. Romanillos
 Science Research Analyst

Verified:


Rico J. Cabangon
 Chief, Engineered Products Development Section

Noted:


Robert A. Natividad
 Chief, Technology Innovation Division